



William Lamborn <william.lamborn@lacity.org>

VTT-72370-CN Hearing Notice and Revised Map

Chen-Yu Kuo <chenyu.kuo@lacity.org>

Mon, May 23, 2016 at 8:51 AM

To: William Lamborn <william.lamborn@lacity.org>

William,

For T-72370 there is no new street lighting required. Please let the deputy advisory agency know that BSL will not attend the hearing on 5/24/2016.

IMPROVEMENT CONDITION: No street lighting improvements if no street widening per BOE improvement conditions. Otherwise relocate and upgrade street lights; one (1) on Havenhurst Dr., three (3) on Sunset Bl., and three (3) on Crescent Heights Bl.

Thank you

[Quoted text hidden]

—

Best regards,

Jimmy Kuo, PE
Bureau of Street Lighting
Private Development Division
Street Lighting Engineering Associate III
[213-847-1551](tel:213-847-1551)




TRACT 72370.pdf

42K

CITY OF LOS ANGELES
INTER-DEPARTMENTAL CORRESPONDENCE

Date: 10/28/2014

To: Mr. Michael LoGrande, Director
Department of City Planning
200 N. Spring St., 5th Flr, MS-395

From:  Jay Wong, Manager
Private Development Division
Bureau of Street Lighting

SUBJECT: STREET LIGHTING REQUIREMENTS FOR DISCRETIONARY ACTIONS

CITY PLANNING CASE No.: TRACT 72370
8150 Sunset Bl.

The Bureau of Street Lighting's recommended condition of approval for the subject city planning case is as follows: (Improvement condition added to S-3 (c) where applicable.)

IMPROVEMENT CONDITION: No street lighting improvements if no street widening per BOE improvement conditions. Otherwise relocate and upgrade street lights; one (1) on Havenhurst Dr., three (3) on Sunset Bl., and three (3) on Crescent Heights Bl.

NOTES:

The quantity of street lights identified may be modified slightly during the plan check process based on illumination calculations and equipment selection.

Conditions set: 1) in compliance with a Specific Plan, 2) by LADOT, or 3) by other legal instrument excluding the Bureau of Engineering conditions, requiring an improvement that will change the geometrics of the public roadway or driveway apron may require additional or the reconstruction of street lighting improvements as part of that condition.