



Luciralia Ibarra &lt;Luciralia.Ibarra@lacity.org&gt;

## Fwd: RP-DEIR Review for 8150 Sunset Boulevard Mixed-Use Project

**Srimal Hewawitharana** <srimal.hewawitharana@lacity.org>

Thu, Oct 15, 2015 at 11:50 AM

To: Karen Hoo <karen.hoo@lacity.org>, Luciralia Ibarra <Luciralia.Ibarra@lacity.org>, William Lamborn <william.lamborn@lacity.org>, David Crook <D.Crook@pcrmet.com>

----- Forwarded message -----

From: **Moosbrugger, Earl** <Earl.Moosbrugger@ladwp.com>

Date: Tue, Oct 13, 2015 at 3:27 PM

Subject: RP-DEIR Review for 8150 Sunset Boulevard Mixed-Use Project

To: "Holloway, Chuck" <Charles.Holloway@ladwp.com>

Cc: "Parker, Nadia" <Nadia.Parker@ladwp.com>, "Eatinger, Stephanie" <Stephanie.Eatinger@ladwp.com>, Srimal Hewawitharana <srimal.hewawitharana@lacity.org>

Hello Mr. Holloway,

Water Resources Development Group submitted a comment on the original DEIR for the 8150 Sunset Boulevard Mixed-Use Project (ENV-2013-2552-EIR) to City Planning on December 30, 2014 (See e-mail below). However, City Planning has requested for us to review and comment on Recirculated Portions of the Draft EIR (RP-DEIR) with generally reduced commercial scope (Alternative 9). Water Resources is submitting to you the following comment to RP-DEIR. This comment reflects our review for matters related to water resources for the project; you may receive additional comments from other divisions at LADWP, separately, referring to other respective areas in RP-DEIR, such as water infrastructure capacity, etc.

Our understanding is that Environmental will compile all comments and submit to the City Planning Department by October 26, 2015.

### Links to NOC and RP-DEIR:

NOC: [http://planning.lacity.org/eir/8150Sunset/DEIR/RDEIR/Notice\\_of\\_Completion&Availability.pdf](http://planning.lacity.org/eir/8150Sunset/DEIR/RDEIR/Notice_of_Completion&Availability.pdf)

RP-DEIR: <http://planning.lacity.org/eir/8150Sunset/deir/rdeir/index.html>.

-

### Water Resources Development Comment:

### 1. PAGE 3-25, 3.0 Corrections and Additions to the Draft EIR, 4.K.1 Utilities and Service Systems – Water Supply

Comment:

Article 4.K.1.1 on page 3-25 of RP-DEIR (see last paragraph on that page) indicates replacement of the last **paragraph** of DEIR page 4.K.1-17 with the text shown in quotes and reproduced immediately below. However, our comment sent to Planning on December 30, 2014, was to replace only the **first two sentences** of the last paragraph of p. 4.K.1-17 of the DEIR with the same text. Therefore, please revise correction shown in 4.K.1.1 of RP-DEIR, accordingly.

"The 54.0 AF per year net increase in water demand generated by the Project would constitute approximately 0.008 percent of the City's total increase in water demand through 2035. Proposed Project conforms with the use and intensity of development permitted by the City's General Plan. Consistency with the demographic projection for the City from the 2012 RTP is required for Proposed Project. City's water demand projection in the 2010 UWMP was developed based on the 2008 Regional Transportation Plan (RTP) demographic projection by the Southern California Association of Governments (SCAG) using the 2000 U.S. Census for the City. The 2012 RTP demographic projection for the City was based on the 2010 U.S. Census, and is lower than the 2008 RTP demographic projection. The region's economic growth is usually a major factor behind net migration and the consequent population growth. The economic recession of 2007-2009 had a negative impact on the region's population growth, resulting in decrease in population growth from 2000 Census to 2010 Census. Our preliminary analysis shows that the City water demand projection to year 2035 based on demographic projection from 2012 RTP using population, housing and employment, as well as water conservation, and weather will be lower than the City's water demand projection in the 2010 UWMP. As a result, City's water supply projections in the 2010 UWMP are sufficient to meet the City's water demand projections based on the 2012 RTP."

If you have any questions, please let me know.

Thank you,

**Earl Moosbrugger, PE**

Resources Development and Supply Assessment Group

Water System Executive Office / Water Resources Section

Los Angeles Department of Water and Power

111 N. Hope Street, Room 1450

Los Angeles, CA 90012

(213) 367-2527

---

**From:** Kwan, Delon

**Sent:** Tuesday, December 30, 2014 9:05 AM

**To:** SRIMAL.HEWAWITHARANA@LACITY.ORG

**Cc:** Planning.enreview@lacity.org; Holloway, Chuck; Parker, Nadia; Moosbrugger, Earl; Nikolajevs, Val

**Subject:** DEIR Review for 8150 Sunset Boulevard Mixed-Use Project

Srimal,

We are submitting to you the following comments to the Draft Environmental Impact Report (DEIR) for the 8150 Sunset Boulevard Mixed-Use Project. These comments reflect our review of the Water Supply chapter only for matters related to water resources for the project; you may receive additional comments from other divisions at LADWP separately to other respective areas in the DEIR such as water infrastructure capacity, etc.

The first two sentences of the last paragraph of p. 4.K.1-17 of the DEIR, see below, appears to imply that the net increase in project water demand expressed as 0.008% percent is within the total 30% increase in total City water demand through 2035 and is a basis for determining that the additional demand is accounted for in LADWP's 2010 UWMP.

Excerpt from DEIR, p. 4.K.1-17:

-

**“The 54.0 AF per year net increase in water demand generated by the Project would constitute approximately 0.008 percent of the City's total increase in water demand through 2035. The proposed Project would fall within the available and projected water supplies of LADWP's 2010 UWMP.”**

However, the methodology for determining whether the project's demand is included in supply projections is not related to that percentage. Instead, it is based on demographic projections included in the Regional Transportation Plan by the Southern California Association of Governments, and by extension, consistency with the City's General Plan. Therefore, additional clarification should be provided as follows:

Replace above Excerpt from DEIR, p. 4.K.1-17 with the following:

-

**The 54.0 AF per year net increase in water demand generated by the Project would constitute approximately 0.008 percent of the City's total increase in water demand through 2035. Proposed Project conforms with the use and intensity of development permitted by the City's General Plan. Consistency with the demographic projection for the City from the 2012 RTP is required for Proposed Project. City's water demand projection in the 2010 UWMP was developed based on the 2008 Regional Transportation Plan (RTP) demographic projection by the Southern California Association of Governments (SCAG) using the 2000 U.S. Census for the City. The 2012 RTP demographic projection for the City was based on the 2010 U.S. Census, and is lower than the 2008 RTP demographic projection. The region's economic growth is usually a major factor behind net migration and the consequent population growth. The economic recession of 2007-2009 had a negative impact on the region's population growth, resulting in decrease in population growth from 2000 Census to 2010 Census. Our preliminary analysis shows that the City water demand projection to year 2035 based on demographic projection from 2012 RTP using population, housing and employment, as well as water conservation, and weather will be lower than the City's water demand projection in the 2010 UWMP. As a result, City's water supply projections in the 2010 UWMP are sufficient to meet the City's water demand**

**projections based on the 2012 RTP.**

Thanks,

**Delon Kwan, P.E.**

LADWP - Water Resources Development

111 N. Hope Street, Room 1460

Los Angeles, CA 90012

(213) 367-2166

(213) 367-1131 Fax

Delon.Kwan@ladwp.com

-----Confidentiality Notice-----

This electronic message transmission contains information from the Los Angeles Department of Water and Power, which may be confidential. If you are not the intended recipient, be aware that any disclosure, copying, distribution or use of the content of this information is prohibited. If you have received this communication in error, please notify us immediately by e-mail and delete the original message and any attachment without reading or saving in any manner.

—  
Srimal P. Hewawitharana  
Environmental Specialist II  
Los Angeles City Planning Department  
EIR Analysis Section, Mail Stop 395  
200 North Spring Street, Suite 750  
Los Angeles, CA 90012  
(213) 978-1359